



**NOTE:**

1. TO ENSURE THE SERVICE VALVE IS STILL ACCESSIBLE, THE RELEVANT AUTHORITY IS TO PROVIDE SIGN OFF / APPROVAL
2. FOR FIRE FIGHTING OPERATIONS, SERVICE VALVE COVERS ARE TO BE REINSTATED IN ACCORDANCE WITH THE WATER SUPPLY CODE OF AUSTRALIA WSA 03-2002-2.2 SYDNEY WATER EDITION VERSION, AND SPECIFICALLY DRAWINGS WAT-1305-V AND WAT-1306-V. ON COMPLETION THE NSWFB ZONE COMMANDERS EAST ONE (TEL: 0419 993 065) SHOULD BE CONTACTED TO ARRANGE TESTING TO ENSURE COMPLIANCE. TYPICALLY, THE CBD HAS SCREW HYDRANTS WHILST OUTSIDE CBD, SPRING HYDRANTS ARE USED.
3. WHERE PIT LID IS GREATER THAN 300mm IN ANY DIRECTION, AN INFILL LID IS TO BE USED.
4. PIT COVERS IN THE FOOTPATH SHALL COMPLY WITH CLASS 'C' LOADING AND FOR TRAFFICABLE AREA PIT COVERS SHALL COMPLY WITH CLASS 'D' LOADING.
5. ALL DIMENSIONS IN MILLIMETRES UNLESS OTHERWISE STATED.

SCALE 1:5