

NOTE:  
THE USE OF THIS TREATMENT IS  
SUBJECT TO TNSW APPROVAL

FLUSH CONCRETE KERB

150mm SQUARE STONE SETTS. 60mm THICK  
WITH 10mm JOINTS OVER 30mm THICK  
MORTAR BEDDING & EXFOLIATED FINISH TO  
IMPROVE TRACTION.

STONE KERB

CONCRETE GUTTER

KERB RAMP

FOOTPATH

1500

FOOTPATH

KERB RAMP

CONCRETE GUTTER

STONE KERB

FLUSH CONCRETE KERB

ROAD WIDTH VARIES

PLAN 1:100

SLURRY BOND COAT (LATICRETE 3701 + CEMENT)  
REFER TO NOTE 2

30mm THICK MORTAR BED.  
REFER TO NOTE 3

10mm WIDE JOINTS  
REFER TO NOTE 5

150mm WIDE FLUSH  
CONCRETE KERB

ROAD

GRANITE SETT ADHESIVE.  
LATICRETE 3701 + LATICRETE 290.  
REFER TO NOTE 4

200mm THICK 32MPa REINFORCED  
CONCRETE BASE. REFER TO NOTE 1

SL82 T&B

100mm THICK DGB20 (98% MMDD)

SECTION 1:10

COMPACTED SUB-GRADE 98%  
STANDARD MDD

#### NOTES:

1. SURFACE SHALL BE MADE PLUMB & TRUE WITHIN 3mm AND SHALL HAVE A WOODEN FLOAT FINISH.
2. MORTAR BED SHALL BE LAID WHILE THE SLURRY BOND COAT IS STILL WET & TACKY.
3. 30mm THICK MORTAR BEDDING FINISHED TO A WOOD FLOAT QUALITY. THE BEDDING SHALL BE OF MODIFIED MORTAR (3:1 SAND:CEMENT) MIXED WITH LATICRETE 3701 MORTAR ADMIX & LATICRETE 226 THICK BED MORTAR AS PER THE MANUFACTURER'S SPECIFICATIONS.
4. THE GRANITE SETTS SHALL BE ADHERED TO THE CURED BEDDING USING A MIX OF LATICRETE 290 PREMIUM MORTAR & LATICRETE 3701 MORTAR ADMIX AS PER THE MANUFACTURER'S SPECIFICATIONS.
5. USE MODIFIED MORTAR (3:1 SAND:CEMENT) MIXED WITH LATICRETE 3701 MORTAR ADMIX, LATICRETE 226 THICK BED MORTAR TO MATCH SETTS COLOUR.
6. ALL DIMENSIONS IN MILLIMETRES UNLESS OTHERWISE STATED.