



- NOTES:**
1. THIS OPTION REQUIRES OBVERT OF THE STORMWATER DRAINAGE PIPE TO BE DEEPER THAN 600mm
 2. THIS DRAWING SHALL BE READ IN CONJUNCTION WITH DRAWING #7.2.1
 3. EXISTING UTILITY SERVICES & DEPTH TO EXISTING STORM WATER SHALL BE VERIFIED BEFORE SPECIFYING THIS OPTION
 4. COMPRESSIVE STRENGTH OF CONCRETE AT 28 DAYS TO BE 32MPa.
 5. CONCRETE STRUCTURES & REINFORCEMENT TO COMPLY WITH AS 3600, AS 4671 & CoS TECHNICAL SPECIFICATIONS.
 6. MINIMUM LAP LENGTH IS TO BE 40 x BAR Ø UNLESS NOTED OTHERWISE.
 7. ALL DIMENSIONS IN MILLIMETRES UNLESS OTHERWISE STATED

SCALE 1:40