

SECTION 1:10

NOTES:

- MINIMUM SIZE OF CONCRETE 460 mm DEEP BY 380 mm SQUARE AND ENLARGED AT THE BOTTOM. WHERE SOLID ROCK IS MET THE DEPTH MAY BE VARIED.
- 2. IN LOCALITIES WHERE THE GROUND IS UNSTABLE THE DIMENSIONS MUST BE INCREASED.
- 3. THE STAINLESS STEEL PIN IS TO PROTRUDE 50 mm ABOVE THE SURFACE OF THE CONCRETE BLOCK.
- 4. THE BUFFER COURSE IS TO BE A 50 mm LAYER OF CRUSHED BRICK, GRAVEL OR COARSE SAND.
- 5. ALL DIMENSIONS IN MILLIMETRES UNLESS OTHERWISE STATED

Date *01.12.19* **Approved** P S

Rev

8.1.4