

NOTES:

- MAINTAIN PAVER BAND WIDTH OF 450mm EXCEPT WHERE REQUIRED TO ADJUST PAVERS TO SUIT SITE CONDITIONS, THEN MIN 400mm BAND WIDTH OVER MIN 5 COURSES IS ACCEPTABLE.
- 2. 1-3mm GAP REQUIRED BETWEEN PAVERS.
- 3. TACTILES AS REQUIRED
- 4. ROAD PAVING TO COMPLY WITH THE FOLLOWING REQUIREMENTS
- 4.1. LAYED ON A 200mm THICK 32mpa REINFORCED (2 LAYERS OF SL82) CONCRETE BASE
- 4.2. A NATURAL STONE PAVER WITH SIMILAR COLOUR TO AUSTRAL BLACK GRANITE PAVING
- 4.3. DESIGNED FOR HEAVY TRAFFIC LOADS EQUIVALENT TO CLASS D
- 4.4. TO MEET THE RMS SKID RESISTANCE REQUIREMENTS
- 4.5. DEMONSTRATED TO HAVE MINIMAL POLISHING OVER TIME DUE TO TRAFFIC LOADS
- 4.6. PAVING TO BE DESIGNED FOR QUICK MAINTENANCE ALLOWING FOR TRAFFIC LOADING AFTER REPAIR
- 4.7. MINIMUM SERVICE LIFE OF PAVEMENT SHALL BE 40 YEARS

STONE SIZES:

TYPE A: 900 x 450 x 60mm TYPE B: 600 x 450 x 60mm TYPE C: 450 x 450 x 60mm

TYPE D: 300 x 450 x 60mm

CJ: CONTRACTION JOINT
EJ: EXPANSION JOINT

PLAN 1:100

NOTE: ALL DIMENSIONS IN MILLIMETRES UNLESS OTHERWISE STATED



GRANITE PAVING
GENERAL ARRANGEMENT PLAN
(GEORGE ST PEDESTRIAN ZONE INTERSECTION)

FOOTWAYS

Rev D
Date 01.12.19
Approved PS 2.2.15