



**NOTE:**

1. ALL EXPOSED CONCRETE SURFACES MUST BE FINISHED WITH A MEDIUM BROOM FINISH GENERALLY PERPENDICULAR TO THE DIRECTION OF TRAVEL.
2. ALL CONCRETE SLABS MUST HAVE A JOINT ALONG THE BUILDING LINE, KERB LINE AND ANY PENETRATIONS (EXCEPT WHEN USING BRICK KERBS).
3. ANY FOOTPATH THAT MAY BE SUBJECT TO VEHICULAR LOADS (SUCH AS GARBAGE TRUCKS IN NARROW LANES OR AT INTERSECTIONS WITH A TIGHT TURNING CIRCLE WHERE VEHICLES MAY MOUNT THE FOOTWAY) MUST HAVE AT LEAST 150mm THICK REINFORCED CONCRETE BASE (SL72).
4. CONCRETE FOOTWAYS TO BE A MINIMUM OF 1.2m WIDE, OR AS DIRECTED BY COUNCIL.
5. TYPICALLY ALLOW FOR EXPANSION JOINTS AT 12m (MAX) SPACING AND CONTRACTION JOINTS AT THE LESSER OF 6m OR 1.5 TIMES THE PAVEMENT WIDTH SPACING.

**LEGEND**

- CJ CONTRACTION JOINTS
- EJ EXPANSION JOINTS
- IJ ISOLATION JOINTS

NOTE: ALL DIMENSIONS IN MILLIMETRES UNLESS OTHERWISE STATED