





DIRECTIONAL TGSI

NOTE:

- ALL WORK SHOULD BE CARRIED OUT IN ACCORDANCE WITH THE AS/NZS 1428.4.1 2009 & CITY'S "SYDNEY STREETS TECHNICAL SPECIFICATION", OR AS DIRECTED BY THE CITY'S REPRESENTATIVE.
- FOR RAMPS WIDER THAN 2 METRES, WIDTH OF TACTILE INDICATORS ON THE RAMP SHOULD BE MINIMUM 1000MM. WHEN WIDTH OF RAMP IS LESS THAN OR EQUAL TO TWO (2) METRES WIDTH OF TACTILE INDICATOR'S BLOCK SHALL MATCH THE RAMP.

TYPE AND COLOUR OF TGSI'S SHALL BE IN ACCORDANCE WITH CITY OF SYDNEY'S TECHNICAL SPECIFICATIONS UNLESS SPECIFIED FOR THE PROJECT. REFER TO DRAWING# 2.7.4 FOR THE COLOUR AND TYPES.

DIFFERENT COLOURS AND TYPES OF TGSI'S MAY BE USED FOR SPECIFIC PROJECTS, IN WHICH CASE CITY OF SYDNEY'S APPROVAL MUST BE OBTAINED IN THE DESIGN PHASE.

NOTE: ALL DIMENSIONS IN MILLIMETRES UNLESS OTHERWISE STATED



TGSI FOOTPATH Rev TYPICAL LAYOUT Dwg No. 01.12.19 Date 2.7.3 SKEWED BOUNDARY LINES Approved PS